



Indiana State
Department of Health
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

May 30, 2012

Country Market Express
453 E. South Boulevard
Crawfordsville, Indiana 47933

Sample Number: 081254964
Registration Number: M7-20701

EMERGENCY STOP-SALE ORDER


A representative of the Weights and Measures Division, Indiana State Department of Health, conducted an octane inspection at Country Market Express motor fuel outlet located at 453 E. South Boulevard, Crawfordsville, Indiana 47933 on May 29, 2012. This inspection revealed that motor fuel sold at this outlet does not comply with the provisions of IC 16-44-3. Specifically, motor fuel described as "Premium" which was posted as having an octane rating of 93 was tested and found to have an actual octane rating of 88.5. This is a violation of IC 16-44-3-11(1).

Pursuant to IC 16-44-3-7, and IC 4-21.5-4, you are hereby ordered to immediately **STOP THE SALE** of all motor fuels described as "Premium" until such time as you have upgraded the fuels in accordance with the requirements of the Weights and Measures, Indiana State Department of Health, or until such time as the octane rating posted on all motor fuel devices dispensing "Premium" is changed to accurately reflect the octane rating of the motor fuel delivered from these dispensers.

This ORDER is effective upon issuance.

If you wish to request a hearing on this ORDER, pursuant to IC 4-21.5-4, you are required to forward a written request to the Indiana State Department of Health, at the office of its Secretary, located at 2525 North Shadeland Avenue, Indianapolis, Indiana 46219 on or before June 29, 2012.

Dated at Indianapolis, Indiana this 30th day of May 2012.



Larry J. Stump, Director
Division of Weights and Measures
2525 N Shadeland Avenue #D3
Indianapolis, Indiana 46219
lstump@isdh.in.gov
(317) 356-7078

HAND DELIVERED BY  ON May 30, 2012.
TO 